



CITY OF COUNTRYSIDE

708-354-1860

building@countryside-il.org

Permit # _____

DISCHARGE OF STORMWATER INFORMATION

COUNTRYSIDE JOB ADDRESS: _____

City Code 7-7-5: B. Permitted Discharge of Stormwater

STORMWATER AND ALL OTHER UNPOLLUTED DRAINAGE SHALL BE DISCHARGED TO SUCH SEWERS AS ARE SPECIFICALLY DESIGNATED AS STORM SEWERS, OR TO A DRAINAGE OUTLET APPROVED BY THE CITY ENGINEER. INDUSTRIAL COOLING WATER OR UNPOLLUTED PROCESS WATERS MAY BE DISCHARGED, UPON APPROVAL OF THE CITY ENGINEER, TO A STORM SEWER OR DRAINAGE OUTLET.

1. ACCEPTABLE DISCHARGES:

A. ALL SUMP PUMPS AND ROOF DOWNSPOUTS INSTALLED FOR THE PURPOSE OF DISCHARGING CLEAR WATERS FROM FOUNDATION DRAINS, GROUND INFILTRATION AND ROOF SURFACE DRAINAGE SHALL EITHER DISCHARGE INTO A PIPE LEADING TO A DRAINAGE OUTLET OR TO THE GROUND SURFACE VIA A "POP UP FITTING", "FRENCH DRAIN", OR OTHER APPROVED DEVICE, OR SHALL DISCHARGE ABOVE THE GROUND. THE DISCHARGE SHALL NOT CREATE A PUBLIC NUISANCE OR ADVERSE DRAINAGE IMPACT. THE FOLLOWING RESTRICTIONS SHALL APPLY:

(1) ALL ABOVEGROUND SUMP PUMP PIPING THAT DO NOT LEAD TO A DRAINAGE OUTLET SHALL DISCHARGE A MINIMUM OF THREE FEET (3') FROM THE BUILDING, AND NOT CLOSER THAN FIFTEEN FEET (15') TO AN INTERIOR SIDE PROPERTY LINE, OR TWENTY FIVE FEET (25') TO A FRONT, REAR, OR CORNER SIDE PROPERTY LINE. THE DISCHARGE SHALL NOT CREATE A PUBLIC NUISANCE OR ADVERSE DRAINAGE IMPACT.

(2) ALL BELOWGROUND SUMP PUMP PIPING THAT DO NOT LEAD TO A DRAINAGE OUTLET SHALL SURFACE TO THE GROUND VIA A "POP UP FITTING", "BUBBLER", "FRENCH DRAIN", OR OTHER DEVICE APPROVED BY THE CITY ENGINEER AND NOT CLOSER THAN FIFTEEN FEET (15') TO AN INTERIOR SIDE PROPERTY LINE, OR TWENTY FIVE FEET (25') TO A FRONT, REAR, OR CORNER SIDE PROPERTY LINE. THE DISCHARGE SHALL NOT CREATE A PUBLIC NUISANCE OR ADVERSE DRAINAGE IMPACT.

(3) ROOF DOWNSPOUTS SHALL DISCHARGE ONTO THE PROPERTY FROM WHICH THE WATER IS ACCUMULATED A MINIMUM OF FIVE FEET (5') FROM THE PROPERTY LINE AND NOT ONTO ADJACENT PROPERTIES. IF THE DISCHARGE FROM THE GUTTER RUNS INTO ABOVE GROUND PIPING, IT SHALL BE CONNECTED PER THE MANUFACTURER'S INSTRUCTIONS AND ALSO BE A MINIMUM OF FIVE FEET (5') FROM THE PROPERTY LINE. THE DISCHARGE SHALL NOT CREATE A PUBLIC NUISANCE OR ADVERSE DRAINAGE IMPACT.

B. WHEN ADEQUATE CAPACITY EXISTS IN THE CITY STORM SEWER SYSTEM, AND WHEN THE HYDRAULIC GRADE OF THE SYSTEM WILL NOT CAUSE A BACKUP OF WATER INTO BUILDINGS ON THE PREMISES OR OTHER PREMISES, AND WHEN REQUIRED BY THE CITY ENGINEER, ROOF DOWNSPOUTS AND/OR SUMP PUMPS SHALL DISCHARGE DIRECTLY INTO THE CITY STORM SEWER LOCATED WITHIN THE PUBLIC RIGHT-OF-WAY OR DRAINAGE AND UTILITY EASEMENT. CONNECTION TO THE CITY STORM SEWER SHALL BE MADE BY A LICENSED PLUMBER. THE CONNECTION SHALL BE MADE BY EITHER TAPPING THE TOP OF THE SEWER LINE WITH AN APPROVED "SLEEVE TEE FITTING" OR BY "CORE DRILLING" INTO A CITY DRAINAGE STRUCTURE.

I have read and understand the above code section and I hereby certify that all sump pump and downspout discharges at the property listed above will be constructed in accordance with Section 7-7-5: B of the City Code. I further certify that upon inspection, should it be determined that any such construction has not been constructed in accordance with this section, the deficiencies will be immediately corrected by the contractor or owner, and prior to occupancy for new construction.

Property Owner:

PRINTED NAME

DATE

SIGNATURE

General Contractor:

PRINTED NAME

DATE

SIGNATURE